



# CERTIFICATE NCS/FI 24609 A1

Our Ref. 252882-1

**Product** Membrane gland  
**Type** GET 3 - 60  
**Trade mark** MAR-CON  
**Certificate Holder/Manufacturer** Trelleborg Industrial Products Finland Oy  
 Kikkerlantie 72  
 FI-38300 SASTAMALA  
 FINLAND  
**Technical information** IP67  
**Other information** See the Appendix to this certificate  
**The product is certified according to the following standard(s)** SFS 4698:2006

**Validity** This certificate is valid until 10 November 2013 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Directive information** The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

**Date of issue** 27 April 2011

**Signature** **SGS Fimko Ltd**

Sixten Lökfors  
 Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at [www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**Manufacturing site(s)** Trelleborg Industrial Products Finland Oy  
Kikkerlöntie 72  
FI-38300 SASTAMALA,  
FINLAND

**Additional information**

Type:	Details:
GET 3-5:	Grey or black Thermoplast for cables Ø 3-5 mm for opening Ø 12 mm and material thickness 1,3 - 5 mm
GET 5-7:	Grey or black Thermoplast for cables Ø 5-7 mm for opening Ø 16 mm and material thickness 1,3 - 5 mm
GET 7-10:	Grey or black Thermoplast for cables Ø 7-10 mm for opening Ø 20 mm and material thickness 1,3 - 5 mm
GET 10-14:	Grey or black Thermoplast for cables Ø 10-14 mm for opening Ø 25 mm and material thickness 1,3 - 5 mm
GET 14-20:	Grey or black Thermoplast for cables Ø 14-20 mm for opening Ø 32 mm and material thickness 1,3 - 5 mm
GET 20-26:	Grey or black Thermoplast for cables Ø 20-26 mm for opening Ø 40 mm and material thickness 1,3 - 5 mm
GET 26-35:	Grey or black Thermoplast for cables Ø 26-35 mm for opening Ø 50 mm and material thickness 1,3 - 5 mm
GET 30-45:	Grey or black Thermoplast for cables Ø 30-45 mm for opening Ø 60 mm and material thickness 1,3 - 5 mm
GET 40-60:	Grey or black Thermoplast for cables Ø 40-60 mm for opening Ø 80 mm and material thickness 1,3 - 5 mm

This certificate replaces NCS/FI certificate No. 24609 dated 10 November 2008, due to updated name of Certificate holder and Manufacturer and changed Manufacturing site.

Supplement to Certificate: **NCS/FI 24609 A1**

Internal ref.  
Sixten Lökfors.

27 April 2011

## NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Denmark, Norway, Sweden

### NOTIFICATION

<b>Certificate holder for Denmark, Norway, Sweden</b>	Trelleborg Industrial Products Finland Oy Kikkerlentie 72 FI-38300 SASTAMALA FINLAND Please send the invoice and the certificate directly to: Attn: Niina Posti, mailto: <a href="mailto:niina.posti@trelleborg.com">niina.posti@trelleborg.com</a>
<b>Safety standard(s) applied</b>	SFS 4698:2006
<b>EMKO TS document(s) considered</b>	Not applicable
<b>EMC requirements</b>	-
<b>The assignment is based on</b>	Testing in own premises from SGS Fimko Ltd.
<b>Limitations or reservations regarding the testing / examination performed</b>	None
<b>Certification marks</b>	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
<b>Production surveillance</b>	Will be carried out by SGS Fimko according to agreed procedures.
<b>Other information</b>	When certificate is applied for in Norway (NEMKO), Denmark (DEMKO) and Sweden (SEMKO) a copy of this certificate and the enclosed material shall be attached to the application.
<b>Test samples must be submitted to the secondary body(ies)</b>	No
<b>Date of issue</b>	27 April 2011

This Notification may be challenged if it is more than 3 years old.

### SGS Fimko Ltd

Signature



Sixten Lökfors  
Project Manager