



CERTIFICATE NCS/FI 28935

Our Ref. 278388-1

Product Flange
Type MC-Multigate 16
Trade mark MAR-CON or logo
Certificate Holder/ Manufacturer Trelleborg Industrial Products Finland Oy
 Kikkerlöntie 72
 FI-38300 SASTAMALA
 FINLAND
Technical information IP54, For cables 1x10-30 mm, 15x10-20 mm,
 IP30, For conduits 1x32 mm, 15x20 mm
Other information Material:
 TPE (thermoplastic elastomer)
 Plastic
 Fixing screws:
 tightening 2,0 Nm

The product is certified according to the following standard(s) SFS 4698:2006
 EN 60670-1:2005 + A1:2013
 EN 61386-21:2004 + A11:2010

Validity This certificate is valid until 16 December 2019 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue 16 December 2014

Signature 
 Sixten Lökfors
 Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.