




CERTIFICATE NCS/FI 29561

Our Ref. 282042-1

Product	Flange
Type	MB 5/11
Trade mark	Trelleborg
Certificate Holder/ Manufacturer	Trelleborg Industrial Products Finland Oy Kikkerlöntie 72 FI-38300 SASTAMALA, FINLAND
Technical information	IP66/IP67, -25 °C For cables: 4x 5-7 mm, 3x 7-10 mm, 2x 10-14 mm, 2x 15-30 mm
Other information	Material: TPE Size B (SFS 2528) B flange
The product is certified according to the following standard(s)	EN 60670-1:2005 + A1:2013 SFS 4698:2006
Validity	This certificate is valid until 26 May 2021 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
Date of issue	26 May 2016
Signature	SGS Fimko Ltd  Sixten Lökfors Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.