CERTIFICATE

Article	Description
5013302	MT 3.0x1200x10000 GY IL DI

Trelleborg Izarra, S.A.U. hereby certifies that our article above mentioned with our reference D664 complies with the requirements of the Standard IEC EN 60243-1:1998

Electric Strength test at Power-frequently:

The test has been performed according to Standard IEC 60243-1:1998, “Electrical Strength of insulating material - Part 1: Tests at power frequencies”.

Test Reference carried out: B126-04-CU-EE-01:

Property	**Unit**	**Standard Value**
Dielectric Strength	kV	30 at 3.0 mm