



Quality Department Certification

Date	08/09/15
Page	1 / 1

CERTIFICATE

<u>Article</u>	<u>Description</u>
D5230007	MT 4.5x1200x10000 GY IL DI

Trelleborg Izarra, S.A.U. hereby certifies that our article above mentioned with our reference D664 comply with the requirements of the Standard IEC EN 60243-1:1998

Electric Strength test at Power-frequently:

The test has been performed according to Standard IEC 60243-1:1998, "Electrical Strength of insulating material - Part 1: Tests at power frequencies".

Test Reference carried out: B126-04-CU-EE-01.

Property	Unit	Standard Value
Dielectric Strength	kV	50 at 4.5 mm



Izarra, 08/09/15
on behalf of PA Elastomer Laminates
Quality Department
María Gutiérrez-Cortines