



**Quality Department Certification**

Date	<b>08/09/15</b>
Page	<b>1 / 1</b>

***CERTIFICATE***

<u>Article</u>	<u>Description</u>
S3206370	MT 4.5x1000x10000 GY IL DI

Trelleborg Izarra, S.A.U. hereby certifies that our article above mentioned with our reference D664 comply with the requirements of the Standard IEC EN 60243-1:1998

Electric Strength test at Power-frequently:

The test has been performed according to Standard IEC 60243-1:1998, "Electrical Strength of insulating material - Part 1: Tests at power frequencies".

Test Reference carried out: B126-04-CU-EE-01.

<b>Property</b>	<b>Unit</b>	<b>Standard Value</b>
Dielectric Strength	kV	50 at 4.5 mm



**Izarra, 08/09/15**  
on behalf of PA Elastomer Laminates  
Quality Department  
María Gutiérrez-Cortines