

SUBJECT: ELECMAT+ (D700):

Trelleborg Izarra, S.A.U. hereby certifies that our reference ELECMAT+ (D700) complies with the requirements of the Standard IEC 61111:2009 (applicable to electrical insulating matting made of elastomer for use as a floor covering for the electrical protection of workers on electrical installations).

The tests have been performed according to IEC 61111:2009:

Date	Test reference	Approved	Thickness
20/12/2018	803884-01/01	CLASS 3	3,20 mm
20/12/2018	803884-01/01	CLASS 4	5.00 mm

Articles related:

THICKNESS	ARTICLE	DESCRIPTION
3,20 mm	SID7000000320A	S D700 3.2X1000X10000 2IL
3,20 mm	SID7000000320B	S D700 3.2X1000X 5000 2IL
3,20 mm	SID70000P03206	S D700 3.2X1000X 1000 2IL
3,20 mm	5606966	S D700 3.2X1000X 600 2IL
3,20 mm	SID7000000320E	S D700 3.2X1200X10000 2IL
5,00 mm	SID7000000500A	S D700 5.0X1000X10000 2IL
5,00 mm	SID7000000500B	S D700 5.0X1000X 5000 2IL
5,00 mm	SID70000P0500A	S D700 5.0X1000X 1000 2IL
5,00 mm	5606967	S D700 5.0X1000X 600 2IL

Izarra, 16/01/19

on behalf of PA Elastomer Laminates

Quality Department



María Gutiérrez-Cortines